

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7300-1483:170

Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Mirtone, 8985 Town Center Parkway, Bradenton, FL 34202
Contact: Jewell Micochero (941) 739-4358 FAX (941) 308-8123

DESIGN: Model *SD-TRK, *SD-TRM, SD-TRK4 and SD-TRM4 remote test/reset station. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, and UL label.

APPROVAL: Listed as remote test/reset station for use with Models SD-CJ or SD-CT series (CSFM Listing No. 3240-1501:154) duct smoke detector controller subassemblies. *Models SD-TRK and SD-RM are for use only with Model SIGA-SD. For indoor use only. Refer to listee's Installation Instruction Manual for details.

XL: 7300-1591:226

*Rev. 01-19-2006



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 28, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division